

Trade Test Assessment Substation Fitting (Power)

Practical Assessment – Substation Fitting Requirements

Instructions

- The assessment must be conducted in a controlled assessment location. This controlled assessment location can be on-site or in an environment that reflects the hazards and risks of a real time working environment. The assessment must be designed to meet the requirements of the Power Network Craftsperson Standard – Level 3
- The technical assessor conducting the assessment must remain in visual contact with the candidate throughout the trade test assessment
- The technical assessor shall ask knowledge questions where competence is not confirmed through observation of natural performance and a record made of the event where relevant

Assessment Requirements

The assessment activity must take a holistic approach and assess a broad range of the skills, knowledge and behaviours developed over the period of the apprenticeship and must in all cases assess the candidate's ability to:

1. Use verbal and written communication methods to plan and organise the range of resources required to carry out substation fitting work, including the materials, tools and equipment
2. Take responsibility for the communication, implementation and monitoring of all safety arrangements required by the activity
3. Carry out all of the following:
 - a. The identification and safe access/egress procedures when working on substation equipment
 - b. Conduct the inspection of substation apparatus
 - c. The maintenance and/or installation of substation apparatus
 - d. Use equipment to carry out the testing of substation apparatus
4. Maintain a safe working environment throughout the duration of the assessment
5. Carry out the receipt, transfer and/or clearance of an operational safety document and maintain and comply with the document's conditions and requirements

Evidence Requirements

- The assessment evidence for the competence assessed by the activity must be retained by the assessment provider for a minimum period of three years after the apprentice's trade test period
- Photographic evidence of the apprentice's assessment work must be retained by the assessment provider for inspection for a minimum period of three years after the apprentice's trade test period

© **Energy & Environment Awards**

All rights reserved. No part of this publication may be reproduced, stored in a retrievable system, or transmitted in any form or by any means whatsoever without prior written permission from the copyright holder.

www.energyenvironmentawards.co.uk